
## *I KRUEGER*

**KBHD & KBVD Direct Drive Blower Coil Unit Configurations** 

JOB NAME ENGINEER CONTRACTOR

TAG \_\_\_

## SUBMITTAL SHEET



## NOTES:

1. All dimensions are in Inches [millimeters]. All dimensions are ±1/4" [6mm]. Metric values are soft conversion.

2. See drawing BCS-KBOD-ACEB0 for rigging hole and base rail details.

3. This drawing is for identification of unit configuration only. See individual unit and section drawings for submittal details.

4. Flat filter rack will be located as required.

UNIT SIZE	Н			L		MB [HU]		MB [VU]	
	HU	VU	W	HU	vu	Α	В	Α	В
08	<b>21</b> [533]	<b>44</b> [1118]	<b>30</b> [762]	<b>40</b> [1016]	<b>24</b> [610]	<b>18</b> [457]	<b>21</b> [533]	<b>18</b> [457]	<b>21</b> [533]
12	<b>21</b> [533]	<b>44</b> [1118]	<b>36</b> [914]	<b>40</b> [1016]	<b>24</b> [610]	<b>18</b> [457]	<b>21</b> [533]	<b>18</b> [457]	<b>21</b> [533]
30	<b>21</b> [533]	<b>44</b> [1118]	<b>44</b> [1118]	<b>40</b> [1016]	<b>24</b> [610]	<b>18</b> [457]	<b>21</b> [533]	<b>18</b> [457]	<b>21</b> [533]
40	<b>22 1/2</b> [572]	<b>50</b> [1270]	<b>50</b> [1270]	<b>40</b> [1016]	<b>30</b> [762]	<b>21</b> [533]	<b>22 1/2</b> [572]	<b>21</b> [533]	<b>21</b> [533]
30	<b>30</b> [762]	<b>56</b> [1422]	<b>59</b> [1499]	<b>46</b> [1168]	<b>30</b> [762]	<b>21</b> [533]	<b>30</b> [762]	<b>21</b> [533]	<b>30</b> [762]
40	<b>30</b> [762]	<b>59</b> [1499]	<b>68</b> [1727]	<b>46</b> [1168]	<b>30</b> [762]	<b>24</b> [610]	<b>30</b> [762]	<b>24</b> [610]	<b>30</b> [762]