

JOB NAME **ENGINEER** CONTRACTOR TAG

1500/1600 SERIES LINEAR BAR GRILLE

CEILING / SIDE WALL / SILL APPLICATION FRAME A, B, C, D, R, AND MF

SUBMITTAL SHEET

NOTES:

- Widths run from 2" to 24" in 1/4" Increments.
 The Minimum Length is 6". The Maximum Length of One Section is 6'-0" Overall. Sections can be Spliced together with Alignment Tabs 2. & Pins, See Form GS0310
- Duct Width = Ordered Width =
- Duct Length = Ordered Length =
- Duct Size = Ceiling Opening Size = Order Size
 Units May be Used for Either Supply or Return Applications.
 Construction is Extruded Aluminum with Steel Fasteners.
- Standard Finish is 44 British White.
- Frame MF comes with Removable core held in place with Core Clips


OPTIONAL ACCESSORIES:


See Form GS0311 For


- **Dampers**
- Linear Straightening Grid
- Blank-Off Strips

See Form GS0304 For:


Mitered Corners.













□ Frame B



□ Frame R



Revision Date: 7/24/2024 Form: GS0300.11

Replaces: GS0300.10

SHEET 1 OF 3

	KR	UF	GF	ZR'
_ التحصيل				

JOB NAME **ENGINEER** CONTRACTOR TAG

1500/1600 SERIES LINEAR BAR GRILLE


CEILING / SIDE WALL / SILL APPLICATION FRAME A, B, C, D, R, AND MF

SUBMITTAL SHEET

FRAME	FLANGE	O.A. FACE		NECK	
STYLE	F	(1) END CAP	(2) END CAPS	(1) END CAP	(2) END CAPS
Α	1 11/32	LENGTH + 7/8	LENGTH + 1 3/4	LENGTH - 5/16	LENGTH - 5/8
В	1 3/32	LENGTH + 5/8	LENGTH + 1 1/4	LENGTH - 5/16	LENGTH - 5/8
С	27/32	LENGTH + 3/8	LENGTH + 3/4	LENGTH - 5/16	LENGTH - 5/8
D	19/32	LENGTH + 1/8	LENGTH + 1/4	LENGTH - 5/16	LENGTH - 5/8
R	11/32	LENGTH - 1/8	LENGTH - 1/4	LENGTH - 5/16	LENGTH - 5/8
MF	1 5/8	LENGTH + 1 1/4	LENGTH + 2 1/2	LENGTH - 5/16	LENGTH - 5/8

NOTES:

- 1. ALIGNMENT TABS & PINS ARE ONLY INCLUDED ON ORDERS OVER 72" IN **LENGTH**
- 2. *MAX BLADE SUPPORT BAR SPACING IS 9"
- 3. FRAME MF HEIGHT **DIMENSION MATCHES** PAGE 1



Replaces: GS0300.10


Form: **GS0300.11**





1500/1600 SERIES LINEAR BAR GRILLE CEILING / SIDE WALL / SILL APPLICATION FRAME A, B, C, D, R, AND MF





SUBMITTAL SHEET













A, B, C, D

*Not recommended for ceiling install due to being secured only by friction



☐ 02 - Concealed Fastening Not compatible with 1600N or 1615N



Revision Date: 7/24/2024 Form: GS0300.11 Replaces: GS0300.10 SHEET 3 OF 3