


DESIGNFLO™/ DFP

JOB NAME **ENGINEER** CONTRACTOR TAG

SUBMITTAL SHEET DFL FRAME FF WITH CONCEALED MOUNTING OPTIONS



DFL NOTES:

- CONSTRUCTION IS EXTRUDED ALUMINUM WITH **ENGINEERED POLYMER COMPONENTS**
- SEE FORM GS0100 FOR ADDITONAL DFL 1 SLOT DETAILS
- SEE FORM GS0102 FOR ADDITIONAL DFL 2 SLOT DETAILS


ACCESSORY OPTIONS:

- HT HORIZONTAL AIR FLOW
- VT VERTICAL AIR FLOW
- 00 NO BLADES

				ONE SLOT			TWO SLOT			
MODEL	SLOT S	FRAME F	HEIGHT H	STACK W	OPENING O	PLENUM P	STACK W	OPENING O	PLENUM P	FRAME M
□ DFL10	1 [25]	1 3/8 [35]	1 11/16 [43]	2 3/4 [70]	3 [76]	3 3/4 [95]	5 3/16 [132]	5 1/2 [140]	6 3/16 [157]	1 7/16 [37]
□ DFL15	1 1/2 [38]	1 5/8 [41]	1 11/16 [43]	3 3/4 [95]	4 [102]	4 3/4 [121]	7 3/16 [183]	7 1/2 [191]	8 3/16 [208]	1 15/16 [49]
□ DFL20	2 [51]	1 7/8 [48]	1 11/16 [43]	4 3/4 [121]	5 [127]	5 3/4 [146]	9 3/16 [233]	9 1/2 [241]	10 3/16 [258]	2 7/16 [62]
□ DFL25	2 1/2 [64]	2 1/8 [54]	2 5/16 [59]	5 3/4 [146]	6 [152]	6 3/4 [171]	11 3/16 [284]	11 1/2 [292]	12 3/16 [310]	2 15/16 [75]
□ DFL30	3 [76]	2 3/8 [60]	2 5/16 [59]	6 3/4 [171]	7 [178]	7 3/4 [197]	13 3/16 [335]	13 1/2 [343]	14 3/16 [360]	3 7/16 [87]

DFP MODELS:





ACCESSORY OPTIONS:

- 1/4" [6], 2LB DENSITY FIBERGLASS INSULATION, ENDCAPS ARE NOT **INSULATED**
- 1/4" [6], CLOSED CELL FIBER FREE INSULATION, ENDCAPS ARE NOT **INSULATED**

ONE SLOT

☐ QUADRANT DAMPER - ADDS 6" [152] TO INLET DEPTH. SEE FORM GC0114

TWO NV SLOT

11	NLET SIZE	C D	
	6 " OVAL	6 1/4 [159]	5 1/4 [133]
	8 " OVAL	9 3/8 [238]	5 1/4 [133]
	10 " OVAL	12 1/2 [318]	5 1/4 [133]
	12 " OVAL	14 1/8 [359]	7 7/8 [200]

DIMENSIONS ARE GIVEN AS INCHES [MM]

			ONL SLOT	IWO IV SLOT
MODEL	NOMINAL LENGTH	O.A. LENGTH	PLENUM WIDTH P	PLENUM WIDTH P
□ DFP 10	24 [610] 36 [914] 48 [1219] 60 [1524]	24 [610] 36 [914] 48 [1219] 60 [1524] 72 [1829]	3 3/4 [95]	6 3/16 [157]
□ DFP 15			4 3/4 [121]	8 3/16 [208]
□ DFP 20			5 3/4 [146]	10 3/16 [258]
□ DFP 25			6 3/4 [171]	12 3/16 [310]
□ DFP 30	72 [1829]		7 3/4 [197]	14 3/16 [360]

Revision Date: 5/2/2024 Form: GC0110.11 GC0110.10 Replaces: